

Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
1	90 th Ave Pump Station	7.7	23.5			Y
2	5910 SE Hazel Pl	8.2	24.0			Y
3	7509 SE Harmony Rd	7.9	23.4			Y
4	5804 SE Kellogg Creek Rd	7.7	22.7			Y
5	14500 SE Vista Ln	7.9	23.6			Y
6	8480 SE Hood St	7.7	22.6			Y
7	12250 SE Capps Rd	7.7	24.0			Y
8	18262 S Arnett Dr	8.2	24.6			Y
9	17308 S Potter Rd	7.9	22.0			Y
10	15937 S Country Air Ct	7.8	22.6			Y

<Has sample met the minimum(s)?

County: Clackamas Agency: REGION 1

DISTRIBUTION

PWS ID 4100187
CLACKAMAS RIVER WATER - CLACKAMAS

Sample Period: June (8th) 2023
Month/Year
 Sample Frequency: Every 6 months
 Distribution Samples required: 7

Number of excursions during this Sample Period = 0
 (Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH
 Alk (Alkalinity)

(N = No = Excursion) Total N's

Print Name: Tracy Triplett
 Signature: *Tracy Triplett*
 Date: July 05, 2023