

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID #	Sample Location	рН	Alk	PO4	Other	Y/N	<has sample<="" th=""><th>County: Clackamas</th><th>Agency: REGION 1</th></has>	County: Clackamas	Agency: REGION 1	
						N	met the			
	90th Ave Rump Station					Ŷ	minimum(s)?	DISTRI	BUTION	
	5910 SE Hazel Pl	8.5				Y				
	7509 SE Harmony Rd	7.8	19.5			γ	PWS ID 4100187			
	5804 SE Kelligg Creek Rd	7.8	19.6			У	CLACKAMAS RIVER WATER - CLACKAMAS			
	14500 SE Vista Ln	7.8	21.3			Ϋ́				
	8480 SE Hood St	7.9	19.9			У				
	12250 SE Capps Rd		20.Z			Ý	Sample Period: <u>December (19th) 2023</u> Month/Year			
	18262 S Arnett Dr					У	Sample Freque	encv: Ev	erv 6 months	
	17308 S Potter Rd	7.7	23.3			Y	Sample Frequency: Every 6 months Distribution Samples required: 7			
	15937 S Country Air Ct	8.7	27.1			У	Distribution 3			
	5						Number of excursions during this Sample Period = $\cancel{\square}$			
							 (Number of locations when any WQP was less than the minimum.) Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period. 			
							Reference			
							Minimum Water Quality			
							Paramete	ers as set	by State:	
							pH 7	.5		
							Alk 16.5 (Alkalinity)			
								(- 5 7	
									2 ,	
(N = No = Excursion) Total N's										
	Date: January 08, 2024									
Send to Drinking Water Program within 10 days after end of sampling period:										

Send to Drinking Water Program within 10 days after end of sampling period: OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/