Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
	90th Ave Pump Station	7.6	24.1			Y
	5910 SE Hazel Place	8.0	25.9			Y
	7509 SE Harmony Rd	7.6	24.2			Y
	5804 SE Kellogg Creek Rd	7.7	23.9			Y
	14500 SE Vista Lane	7.6	21.8			Y
	8480 SE Hood Street	7.6	24.5			Y
	12250 SE Capps Road	7.6	24.6			Y
	18262 S Arnett Drive	8.7	26.8			Y
	17308 S. Potter Road	7.7	23.5			Y
	15937 S. Country Air Ct	7.7	24.6			Y

(N = No = Excursion) **Total N's** 0

<Has sample met the minimum(s)?

County: Clackamas

Agency: REGION 1

DISTRIBUTION

PWS ID 4100187

CLACKAMAS RIVER WATER - CLACKAMAS

Sample Period: December 2025
Month/Year

Sample Frequency: Every 6 months

Distribution Samples required: 7

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.5

Alk 16.5 *(Alkalinity)*

Print Name: Tracy Triplett

Signature: Tracy Triplett

Date: 01/07/2026 (503) 793-3685

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: http://healthoregon.org/dwp/