

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6				Y
3	7.6	20.3			Y
4	7.6	20.7			Y
5	7.6	19.9			Y
6	7.6	19.0			Y
7	7.7	17.9			Y
8	7.6	17.1			Y
9	7.6	18.8			Y
10	7.6	18.8			Y
11	7.6	19.3			Y
12	7.6	19.0			Y
13	7.6	19.5			Y
14	7.6	19.2			Y
15	7.6				Y
16	7.6				Y
17	7.5	19.8			Y
18	7.6	20.0			Y
19	7.6	20.7			Y
20	7.6				Y
21	7.6	19.5			Y
22	7.6				Y
23	7.6				Y
24	7.6	18.7			Y
25	7.6	19.6			Y
26	7.6				Y
27	7.6				Y
28	7.7	20.7			Y
29	7.6				Y
30	7.6				Y
31	7.6	21.0			Y

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100187

**CLACKAMAS RIVER WATER -
 CLACKAMAS**

Sample period: January 2022
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.5

Print Name: Tracy Triplett

Signature: *Tracy Triplett*

Date & Phone#: 02-01-2022 (503) 793-3685

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0