

Day	pH	Alk	Phos	Other	Y/N
1	7.6	22.0			Y
2	7.6	22.9			Y
3	7.6				Y
4	7.6				Y
5	7.6	23.0			Y
6	7.6	27.2			Y
7	7.6				Y
8	7.6	24.1			Y
9	7.6	24.0			Y
10	7.6				Y
11	7.6				Y
12	7.6	22.9			Y
13	7.6				Y
14	7.6	21.4			Y
15	7.6				Y
16	7.6	21.6			Y
17	7.6				Y
18	7.6				Y
19	7.6	23.6			Y
20	7.6	23.8			Y
21	7.6	22.8			Y
22	7.6	21.6			Y
23	7.6	23.1			Y
24	7.6				Y
25	7.6				Y
26	7.6				Y
27	7.6	18.7			Y
28	7.6	16.5			Y
29	7.6	17.1			Y
30	7.6	17.5			Y
31	7.6				Y

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100187**

**CLACKAMAS RIVER WATER - CLACKAMAS**

**Sample period:** December 2022  
Month/Year

**Number of excursions during this month:** 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.5  
Alk 16.5 (Alkalinity)

**Print Name:** Tracy Triplett

**Signature:** Tracy Triplett

**Date & Phone#:** 01/09/2023 (503) 793-3685

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0