

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6				Y
3	7.6	20.0			Y
4	7.6	19.9			Y
5	7.6	19.7			Y
6	7.6				Y
7	7.6				Y
8	7.6				Y
9	7.6				Y
10	7.6	21.1			Y
11	7.6				Y
12	7.6	21.7			Y
13	7.6				Y
14	7.6				Y
15	7.6				Y
16	7.6				Y
17	7.6				Y
18	7.6	20.0			Y
19	7.6	20.6			Y
20	7.6	21.5			Y
21	7.6				Y
22	7.6				Y
23	7.6				Y
24	7.6	22.3			Y
25	7.6	23.3			Y
26	7.6	23.4			Y
27	7.6	23.3			Y
28	7.6				Y
29	7.6				Y
30	7.6	23.4			Y
31	7.6	22.7			Y

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100187

**CLACKAMAS RIVER WATER -
CLACKAMAS**

Sample period: January 2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.5
 Alk 16.5 (Alkalinity)

Print Name: Tracy Triplett

Signature:

Date & Phone#: 02/03/2023 (503) 793-3685

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0