Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
1	90th Ave Pump Station	7.6	21.8			Y
2	5910 SE Hazel Pl	8.5	24.7			Y
3	7509 SE Harmony Rd	8.0	22.9			Y
4	5804 SE Kellogg Creek Rd	8.2	22.4			Y
5	14500 SE Vista Ln.	8.4	24.4			Y
6	8480 SE Hood St.	7.8	21.1			Y
7	12250 SE Capps Rd.	7.9	21.9			Y
8	18262 S Arnett Dr.	8.3	23.9			Y
9	17308 S Potter Rd	7.8	22.0			Y
10	15937 S. Country Air Rd	8.2	23.9			Y
11	90th Ave Pump St.	7.7	20.7			Y
12	5910 SE Hazel Pl	8.3	22.3			Y
13	7509 SE Harmony Rd	7.9	23.5			Y
14	5804 SE Kellogg Creek Rd	8.0	22.0			Y
15	14500 SE Vista Ln	8.2	22.6			Y
16	8480 SE Hood St.	7.7	21.0			Y
17	12250 SE Capps Rd	7.8	20.8			Y
18	18262 S Arnett Dr.	8.2	23.3			Y
19	17308 S. Potter Rd	7.8	21.7			Y
20	15937 S. Country Air Rd	7.9	22.6			Y

12-3-21

12-14-21

(N = No = Excursion) **Total N's** 0

<Has sample met the minimum(s)?

County: Clackamas

Agency: REGION 1

DISTRIBUTION

PWS ID 4100187

CLACKAMAS RIVER WATER - CLACKAMAS

Sample Period: Dec. 2021
Month/Year

Sample Frequency: Every 6 months

Distribution Samples required: 7

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.5

Print Name: Tracy Triplett

Signature Tracy Triplett

Date: January 10, 2022

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: http://healthoregon.org/dwp/