

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
1	90 th Ave Pump Station	7.6	25.0			Y
2	5910 SE Hazel Pl	8.0	30.1			Y
3	7509 SE Harmony Rd	7.6	26.0			Y
4	5804 SE Kellogg Creek Rd	7.7	26.0			Y
5	14500 SE Vista Ln	8.1	28.0			Y
6	8480 SE Hood St	7.6	26.0			Y
7	12250 SE Capps Rd	7.6	25.0			Y
8	18262 S Arnett Dr	8.0	28.0			Y
9	17308 S Potter Rd	7.6	26.0			Y
10	15937S Country Air Ct	7.8	27.3			Y

(N = No = Excursion) Total N's 0

<Has sample met the minimum(s)?

County: Clackamas Agency: REGION 1

DISTRIBUTION

PWS ID 4100187
CLACKAMAS RIVER WATER - CLACKAMAS

Sample Period: December 2022
Month/Year

Sample Frequency: Every 6 months
 Distribution Samples required: 7

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.5
 Alk 16.5 (Alkalinity)

Print Name: Tracy Triplett
 Signature: Tracy Triplett
 Date: January 09, 2023