



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Table with columns: Day, pH, Alk, Phos, SM, Y/N. Rows include data for 4-1 (pH 7.3) and 4-25 (pH 7.4), with Y/N marked as Y.

Form containing: County: Columbia Agency: REGION 1, ENTRY POINT EP-C, PWS ID 4100203, COLUMBIA CITY MUN WATERWORKS, Sample period: April 2022 Month/Year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference Minimum Water Quality Parameter(s) as set by State: pH 7.2

Print Name: Micah Rogers
Signature: Micah Rogers
Date: 5/9/22

Send to DWP within 10 days after end of sampling period

0 = N = Excursion Total N's 0