



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SM	YN
5-11	7.4				Y
5-25	7.4				Y

Have minimums been met for this day?

County: Columbia Agency: REGION 1

ENTRY POINT
EP-C

PWS ID 4100203
COLUMBIA CITY MUN WATERWORKS

Sample period: May 2022
Month/Year

Number of excursions during this month: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:
 pH

Print Name: Nicah Rogers
 Signature: *Nicah Rogers*
 Date: 6/6/22

Send to DWP within 10 days after end of sampling period

0 - N = Excursion Total N's