



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SM	Y/N
8/11	7.6				Y
8/25	7.7				Y

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**

**EP-C**

**PWS ID 4100203**

**COLUMBIA CITY MUN WATERWORKS**

Sample period: August 2022  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

**Reference**

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name: Micha Rogers

Signature: Micha Rogers

Date: 9/6/22

Send to DWP within 10 days after end of sampling period

to = N = Excursion) Total N's 0