DHS
Oregon Department of Human Services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sil	Y/N
11/11	7.8				Y
11/25	7.7				Y

(o = N = Excursion) Total N's: 0

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

ENTRY POINT

EP-C

PWS ID 4100203

COLUMBIA CITY MUN WATERWORKS

Sample period: November 2022
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Micah Rogers

Signature: Micah Rogers

Date: 12/9/22

Send to DWP within 10 days after end of sampling period