

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11	7.7				
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25	7.7				
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	2	0	3
---	---	---	---	---

System Name: Columbia City Mun. Water

Entry Point: EP-C

Sample Period: February, 2023  
Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

--

 (Alkalinity)

PO4 

--

 (Orthophosphate)

Other 

--

 (\_\_\_\_\_)

Print Name: Micah Rogers

Signature: Micah Rogers

Date: 3/9/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0