

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11	7.7				Y
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25	7.6				Y
26					
27					
28					
29					
30					
31					

(No = N = Excursion) Total N's 

<<Have  
minimums  
been met for  
this day?

### ENTRY POINT

PWS ID: 41 0 0 2 0 3

System Name: Columbia City Mun. Water

Entry Point: EP-C

Sample Period: September 2025

Month/Year

Number of excursions\* during this month: 

(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months: 

(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative )

For OHA use only

Minimum Water Quality  
Parameters as set by

pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	(_____)

Print Name: Micah Rogers

Signature: 

Date: 10/9/25

Send to DWP within 10 days after end of  
sampling period