



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

RECEIVED  
MAY 05 2023  
Certification  
Drinking Water Services  
RECEIVED

Day	pH	Alk	Phos	Other	Y/N
1	7.0				Y
2	7.1				Y
3	7.0	20			Y
4	7.0				Y
5	7.0				Y
6	7.0				Y
7	7.0				Y
8	7.0				Y
9	7.1				Y
10	7.0	30			Y
11	7.0				Y
12	7.0				Y
13	7.0				Y
14	7.0				Y
15	7.1				Y
16	7.0				Y
<del>17</del>					
18	7.0				Y
19	7.1	30			Y
20	7.0				Y
21	7.0				Y
22	7.1				Y
23	7.1				Y
24	7.0	30			Y
25	7.0				Y
26	7.1				Y
27	7.1				Y
28	7.0				Y
29	7.0				Y
30	7.0				Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT** MAY 05 2023

**PWS ID: 41 00213** Certification Drinking Water Services

**System Name:** Coquille, City of

**Entry Point:** EP-A

**Sample Period:** 45017

Apr-23

**Number of excursions during this month :** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameter as set by State:**

pH	<b>7.0</b>	
Alk	<b>16</b>	<i>(Alkalinity)</i>
Phos		<i>(Phos. Max)</i>
Other		<i>(_____)</i>

**Print Name:** Ray Doan

**Signature:** *Ray Doan*

**Date:** 5/2/23

Send to Drinking Water Program within 10 days after end of sampling period.  
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350  
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>