



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.1				Y
2	7.1				Y
3	7.1				Y
4	7.1				Y
5	7.0				Y
6	7.0				Y
7	7.0	43			Y
8	7.1				Y
9	7.1				Y
10	7.1				Y
11	7.1				Y
12	7.1				Y
13	7.2				Y
14	7.0	45			Y
15	7.0				Y
16	7.0				Y
17	7.0				Y
18	7.1				Y
19	7.1				Y
20	7.1				Y
21	7.0	64			Y
22	7.1				Y
23	7.1				Y
24	7.1				Y
25	7.1				Y
26	7.0				Y
27	7.0				Y
28	7.0	47			Y
29	7.0				Y
30	7.0				Y
31	7.0				Y
					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00213

System Name: Coquille, City of

Entry Point: EP-A

Sample Period: Oct-24

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.0	
Alk	16	<i>(Alkalinity)</i>
Phos		<i>(Phos. Max)</i>
Other		<i>(_____)</i>

Print Name: Gary Degit

Signature: *Gary Degit*

Date: 10/2/24

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>