

### Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.0				Y
2	7.0				Y
3	7.0				Y
4	7.0				Y
5	7.0	18			Y
6	7.0				Y
7	7.0				Y
8	7.0				Y
9	7.0				Y
10	7.0				Y
11	7.0				Y
12	7.2	30			Y
13	7.0				Y
14	7.0				Y
15	7.0				Y
16	7.0				Y
17	7.0				Y
18	7.0				Y
19	7.0	25			Y
20	7.0				Y
21	7.0				Y
22	7.1				Y
23	7.0				Y
24	7.0				Y
25	7.0				Y
26	7.0	30			Y
27	7.0				Y
28	7.0				Y
29	7.0				Y
30	7.0				Y
31	7.0				Y
					0

<<Have minimums been met for this day?

#### ENTRY POINT

**PWS ID: 41 00213**

**System Name:** Coquille, City of

**Entry Point:** EP-A

**Sample Period:** May-25

**Number of excursions during this month :** 0

*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 1

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

#### Minimum Water Quality Parameter as set by State:

pH	<u>7.0</u>	
Alk	<u>16</u>	(Alkalinity)
Phos		(Phos. Max)
Other		( )

**Print Name:** Gary Dagitt

**Signature:** [Signature]

**Date:** 5/3/25

Send to Drinking Water Program within 10 days after end of sampling period.

OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350

Phone: (971) 673-0405

Website: <http://healthoregon.org/dwp/>