



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.5				Y
3	7.5	21.4			Y
4	7.5				Y
5	7.5				Y
6	7.5				Y
7	7.5				Y
8	7.4				Y
9	7.4				Y
10	7.5	21.7			Y
11	7.5				Y
12	7.6				Y
13	7.6				Y
14	7.5				Y
15	7.6				Y
16	7.5				Y
17	7.5	24.5			Y
18	7.5				Y
19	7.5				Y
20	7.6				Y
21	7.6				Y
22	7.6				Y
23	7.5				Y
24	7.5	26.5			Y
25	7.5				Y
26	7.6				Y
27	7.6				Y
28	7.5				Y
29	7.5				Y
30	7.6				Y
31	7.7				0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00213

System Name: Coquille, City of

Entry Point: EP-A

Sample Period: Nov-25

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality

Parameter as set by State:

pH	<u>7.0</u>	
Alk	<u>16</u>	(Alkalinity)
Phos		(Phos. Max)
Other		()

Print Name: Gary Dagit

Signature:

Date: 12/1/25

Send to Drinking Water Program within 10 days after end of sampling period.

OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350

Phone: (971) 673-0405

Website: <http://healthoregon.org/dwp/>