



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.0	20			Y
2	7.0				Y
3	7.0				Y
4	7.0				Y
5	7.0				Y
6	7.1				Y
7	7.0				Y
8	7.2	20			Y
9	7.0				Y
10	7.0				Y
11	7.0				Y
12	7.0				Y
13	7.0				Y
14	7.0				Y
15	7.0	25			Y
16	7.0				Y
17	7.0				Y
18	7.0				Y
19	7.0				Y
20	7.0				Y
21	7.0				Y
22	7.0	20			Y
23	7.0				Y
24	7.0				Y
25	7.0				Y
26	7.0				Y
27	7.0				Y
28	7.0				Y
29	7.0	20			Y
30	7.0				Y
31	7.0				Y
(No=N=Excursion)Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00213

System Name: Coquille, City of

Entry Point: EP-A

Sample Period: 44256
Mar-21

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

RECEIVED

APR 08 2021

For OHA use only Data Mgmt & Compliance
Drinking Water Program

**Minimum Water Quality
Parameter as set by State:**

pH	7.0	
Alk	16	(Alkalinity)
Phos		(Phos. Max)
Other		()

Print Name: ROY ROAN

Signature: *[Signature]*

Date: 4/2/21

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>
 Page 1 of 2