



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.0				Y
2	7.0				Y
3	7.0				Y
4	7.1				Y
5	7.0	25			Y
6	7.0				Y
7	7.0				Y
8	7.0				Y
9	7.0				Y
10	7.0				Y
11	7.0				Y
12	7.0	25			Y
13	7.0				Y
14	7.0				Y
15	7.1				Y
16	7.0				Y
17	7.0				Y
18	7.0				Y
19	7.0	25			Y
20	7.0				Y
21	7.0				Y
22	7.0				Y
23	6.9				N
24	7.0				Y
25	7.0				Y
26	7.0	25			Y
27	7.0				Y
28	7.0				Y
29	7.0				Y
30	7.0				Y
(No=N=Excursion)Total N's					1

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00213

System Name: Coquille, City of

Entry Point: EP-A

Sample Period: 44287

Apr-21

Number of excursions during this month : 1
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 01
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)



For OHA use only

*Data Mgmt & Compliance
Drinking Water Program*

Minimum Water Quality Parameter as set by State:

pH	7.0	
Alk	16	<i>(Alkalinity)</i>
Phos		<i>(Phos. Max)</i>
Other		<i>(_____)</i>

Print Name: Ray Doan

Signature: *Ray Doan*

Date: 5/3/21