



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.0				Y
2	7.1				Y
3	7.0				Y
4	7.0	60			Y
5	7.0				Y
6	7.0				Y
7	7.0				Y
8	7.0				Y
9	7.0				Y
10	7.0				Y
11	7.0	50			Y
12	7.0				Y
13	7.0				Y
14	7.0				Y
15	7.0				Y
16	7.0				Y
17	7.1				Y
18	7.0	50			Y
19	7.0				Y
20	7.0				Y
21	7.1				Y
22	7.0				Y
23	7.0				Y
24	7.0				Y
25	7.0	55			Y
26	7.0				Y
27	7.0				Y
28	7.0				Y
29	7.1				Y
30	7.0				Y
31	7.1				Y
(No=N=Excursion)Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00213

System Name: Coquille, City of

Entry Point: EP-A

Sample Period: 44470
Oct-21

Number of excursions during this month : 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

RECEIVED
 NOV 05 2021

For OHA use only

Data Mgmt & Compliance
 Drinking Water Program

**Minimum Water Quality
 Parameter as set by State:**

pH	<u>7.0</u>	
Alk	<u>16</u>	(Alkalinity)
Phos		(Phos. Max)
Other		()

Print Name: Ray Doan

Signature: [Signature]

Date: 11/2/21

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>