



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.0				Y
2	7.0				Y
3	7.0				Y
4	7.1				Y
5	7.0				Y
6	7.0	30			Y
7	7.1				Y
8	7.0				Y
9	7.0				Y
10	7.1				Y
11	7.1				Y
12	7.1				Y
13	7.0				Y
14	7.0	30			Y
15	7.1				Y
16	7.2				Y
17	7.1				Y
18	7.0				Y
19	7.1				Y
20	7.0				Y
21	7.0	25			Y
22	7.0				Y
23	7.1				Y
24	7.1				Y
25	7.2				Y
26	7.1				Y
27	7.0	30			Y
28	7.0				Y
29	7.0				Y
30	7.1				Y
31	7.1				Y
(No=N=Excursion)Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00213

System Name: Coquille, City of

Entry Point: EP-A

Sample Period: 44531

Dec-21

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

RECEIVED

JAN 07 2021

Data Mgmt & Compliance
Drinking Water Program

For OHA use only

**Minimum Water Quality
Parameter as set by State:**

pH	7.0	
Alk	16	<i>(Alkalinity)</i>
Phos		<i>(Phos. Max)</i>
Other		<i>()</i>

Print Name: Ray Doan

Signature: *Ray Doan*

Date: 1/3/22

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350