



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|---------------------------|-----|-----|------|-------|----------|
| 1 | 7.0 | | | | Y |
| 2 | 7.2 | | | | Y |
| 3 | 7.1 | | | | Y |
| 4 | 7.2 | | | | Y |
| 5 | 7.2 | 60 | | | Y |
| 6 | 7.1 | | | | Y |
| 7 | 7.1 | | | | Y |
| 8 | 7.1 | | | | Y |
| 9 | 7.1 | | | | Y |
| 10 | 7.1 | | | | Y |
| 11 | 7.1 | | | | Y |
| 12 | 7.1 | 60 | | | Y |
| 13 | 7.1 | | | | Y |
| 14 | 7.1 | | | | Y |
| 15 | 7.1 | | | | Y |
| 16 | 7.1 | | | | Y |
| 17 | 7.1 | | | | Y |
| 18 | 7.1 | | | | Y |
| 19 | 7.1 | 65 | | | Y |
| 20 | 7.1 | | | | Y |
| 21 | 7.1 | | | | Y |
| 22 | 7.1 | | | | Y |
| 23 | 7.1 | | | | Y |
| 24 | 7.1 | | | | Y |
| 25 | 7.1 | | | | Y |
| 26 | 7.1 | 70 | | | Y |
| 27 | 7.1 | | | | Y |
| 28 | 7.1 | | | | Y |
| 29 | 7.1 | | | | Y |
| 30 | 7.1 | | | | Y |
| (No=N=Excursion)Total N's | | | | | 0 |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00213

System Name: Coquille, City of

Entry Point: EP-A

Sample Period: 44805

Sep-22

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

| | | |
|-------|------------|---------------------|
| pH | 7.0 | |
| Alk | 16 | <i>(Alkalinity)</i> |
| Phos | | <i>(Phos. Max)</i> |
| Other | | <i>(_____)</i> |

Print Name: Ray Doan

Signature: [Signature]

Date: 10/3/22

Send to Drinking Water Program within 10 days after end of sampling period.

OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350

Phone: (971) 673-0405

Website: <http://healthoregon.org/dwp/>