



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.2				Y
3	7.1	60			Y
4	7.1				Y
5	7.1				Y
6	7.1				Y
7	7.1				Y
8	7.3				Y
9	7.3				Y
10	7.1	60			Y
11	7.1				Y
12	7.1				Y
13	7.1				Y
14	7.2				Y
15	7.1				Y
16	7.2				Y
17	7.1	70			Y
18	7.1				Y
19	7.1				Y
20	7.1				Y
21	7.1				Y
22	7.1				Y
23	7.2				Y
24	7.1	65			Y
25	7.1				Y
26	7.1				Y
27	7.1				Y
28	7.1				Y
29	7.1				Y
30	7.1				Y
31	7.1	50			Y
(No=N=Excursion) Total N's					<b>0</b>

<<Have minimums been met for this day?

**ENTRY POINT**

**PWS ID: 41 00213**

**System Name:** Coquille, City of

**Entry Point:** EP-A

**Sample Period:** 44835

*Oct-22*

**Number of excursions during this month :** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameter as set by State:**

pH	<b>7.0</b>	
Alk	<b>16</b>	<i>(Alkalinity)</i>
Phos		<i>(Phos. Max)</i>
Other		<i>( )</i>

RECEIVED

NOV 09 2022

Data Mgmt & Compliance  
Drinking Water Program

**Print Name:** RAY DOAN

**Signature:** *Ray Doan*

**Date:** 11/1/22