



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.0	35			Y
2	7.0				Y
3	7.1				Y
4	7.0				Y
5	7.0				Y
6	7.0				Y
7	7.0				Y
8	7.0	35			Y
9	7.0				Y
10	7.0				Y
11	7.0				Y
12	7.0				Y
13	7.1				Y
14	7.0				Y
15	7.0	30			Y
16	7.0				Y
17	7.0				Y
18	7.0				Y
19	7.0				Y
20	7.1				Y
21	7.0				Y
22	7.1	25			Y
23	7.0				Y
24	7.0				Y
25	7.0				Y
26	7.0				Y
27	7.0				Y
28	7.0				Y
29	7.0	30			Y
30	7.0				Y
31	7.1				Y

(No=N=Excursion)Total N's **0**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00213

System Name: Coquille, City of
 Entry Point: EP-A
 Sample Period: 45047
May-23

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.0	
Alk	16	(Alkalinity)
Phos		(Phos. Max)
Other		()

Print Name: Ray Doan
 Signature:
 Date: 6/1/23

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>