



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

| Day | pH  | Alk | Phos | Sili | Y/N |
|-----|-----|-----|------|------|-----|
| 1   | 7.4 |     |      |      | Y   |
| 2   | 7.4 |     |      |      | Y   |
| 3   | 7.4 |     |      |      |     |
| 4   | 7.4 |     |      |      |     |
| 5   | 7.3 |     |      |      |     |
| 6   | 7.3 |     |      |      |     |
| 7   | 7.4 |     |      |      |     |
| 8   | 7.4 |     |      |      |     |
| 9   | 7.3 |     |      |      |     |
| 10  | 7.3 |     |      |      |     |
| 11  | 7.3 |     |      |      |     |
| 12  | 7.4 |     |      |      |     |
| 13  | 7.4 |     |      |      |     |
| 14  | 7.4 |     |      |      |     |
| 15  | 7.4 |     |      |      |     |
| 16  | 7.3 |     |      |      |     |
| 17  | 7.3 |     |      |      |     |
| 18  | 7.3 |     |      |      |     |
| 19  | 7.3 |     |      |      |     |
| 20  | 7.3 |     |      |      |     |
| 21  | 7.3 |     |      |      |     |
| 22  | 7.4 |     |      |      |     |
| 23  | 7.4 |     |      |      |     |
| 24  | 7.4 |     |      |      |     |
| 25  | 7.4 |     |      |      |     |
| 26  | 7.5 |     |      |      |     |
| 27  | 7.4 |     |      |      |     |
| 28  | 7.4 |     |      |      |     |
| 29  | 7.4 |     |      |      |     |
| 30  | 7.4 |     |      |      |     |
| 31  | 7.4 |     |      |      |     |

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

## ENTRY POINT

### EP-A

**PWS ID 4100214**

**GARDEN VALLEY WATER ASSN**

Sample period: Jan. 2021  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*



Reference Data Mgmt & Compliance  
Drinking Water Program

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.2

Print Name: Rag Doan  
 Signature: [Signature]  
 Date Phone#: 2/1/21 541-808-4074

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's 0