



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.3				Y
2	7.3				Y
3	7.4				
4	7.4				
5	7.4				
6	7.4				
7	7.4				
8	7.4				
9	7.4				
10	7.4				
11	7.4				
12	7.4				
13	7.4				
14	7.4				
15	7.4				
16	7.4				
17	7.4				
18	7.4				
19	7.2				
20	7.2				
21	7.2				
22	7.2				
23	7.2				
24	7.2				
25	7.2				
26	7.2				
27	7.2				
28	7.2				
29	7.2				
30	7.2				
31	7.2				

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

ENTRY POINT

EP-A

PWS ID 4100214

GARDEN VALLEY WATER ASSN

Sample period: May 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

RECEIVED

JUN 09 2021

Data Mgmt & Compliance
Drinking Water Program

Print Name: Ray Duan

Signature: [Signature]

Date Phone#: 6/2/21 841-808-4074

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's 0