



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.2				Y
2	7.3				Y
3	7.3				Y
4	7.3				Y
5	7.3				Y
6	7.3				Y
7	7.3				Y
8	7.3				Y
9	7.3				Y
10	7.3				Y
11	7.3				Y
12	7.2				Y
13	7.2				Y
14	7.2				Y
15	7.2				Y
16	7.2				Y
17	7.2				Y
18	7.2				Y
19	7.2				Y
20	7.2				Y
21	7.2				Y
22	7.2				Y
23	7.3				Y
24	7.3				Y
25	7.3				Y
26	7.3				Y
27	7.3				Y
28	7.3				Y
29	7.3				Y
30	7.3				Y
31	7.3				Y

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

## ENTRY POINT EP-A

### PWS ID 4100214 GARDEN VALLEY WATER ASSN

Sample period: July 2021  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

RECEIVED

AUG 04 2021

Data Mgmt & Compliance  
Drinking Water Program

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name: Ray Doan

Signature: *Ray Doan*

Date Phone#: 8/2/21 541-808-4074

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's 0