



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.6				Y
2	7.6				Y
3	7.6				Y
4	7.6				Y
5	7.6				Y
6	7.6				Y
7	7.6				Y
8	7.5				Y
9	7.5				Y
10	7.5				Y
11	7.5				Y
12	7.5				Y
13	7.5				Y
14	7.5				Y
15	7.5				Y
16	7.5				Y
17	7.5				Y
18	7.5				Y
19	7.5				Y
20	7.5				Y
21	7.6				Y
22	7.6				Y
23	7.6				Y
24	7.6				Y
25	7.6				Y
26	7.6				Y
27	7.6				Y
28	7.6				Y
29	7.6				Y
30	7.6				Y
31					

Have minimums been met for this day?

County: Clatsop Agency: REGION 2

**ENTRY POINT
EP-A**

PWS ID 4100214

GARDEN VALLEY WATER ASSN

Sample period: Sept 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

R
OCT 04 2021
D

Data Mgmt & Compliance
Drinking Water Program

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: _____
Signature: Stephen E Pennington
Date: Oct 14 2021

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's 0