



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.2				Y
2	7.2				Y
3	7.2				
4	7.2				
5	7.2				
6	7.2				
7	7.2				
8	7.2				
9	7.2				
10	7.2				
11	7.2				
12	7.2				
13	7.2				
14	7.2				
15	7.2				
16	7.3				
17	7.3				
18	7.3				
19	7.3				
20	7.3				
21	7.3				
22	7.3				
23	7.3				
24	7.3				
25	7.3				
26	7.3				
27	7.3				
28	7.3				
29	7.3				
30	7.3				
31					

Have minimums been met for this day?

County: Coos      Agency: REGION 2

## ENTRY POINT EP-A

**PWS ID 4100214**  
**GARDEN VALLEY WATER ASSN**

Sample period: Nov 2021  
Month/Year

**Number of excursions during this month:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.2

RECEIVED  
 DEC 04 2021  
 Data Mgmt & Compliance  
 Drinking Water Program

**Print Name:** Ray Doan  
**Signature:** [Signature]  
**Date Phone#:** 12/1/21  
**Send to DWP within 10 days after end of sampling period**

**No = N = Excursion) Total N's** 0