



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.2				Y
2	7.2				Y
3	7.2				Y
4	7.4				Y
5	7.2				Y
6	7.2				Y
7	7.3				Y
8	7.3				Y
9	7.3				Y
10	7.3				Y
11	7.3				Y
12	7.4				Y
13	7.4				Y
14	7.4				Y
15	7.3				Y
16	7.3				Y
17	7.4				Y
18	7.5				Y
19	7.5				Y
20	7.5				Y
21	7.5				Y
22	7.5				Y
23	7.4				Y
24	7.4				Y
25	7.4				Y
26	7.4				Y
27	7.4				Y
28	7.4				Y
29	7.4				Y
30	7.4				Y
31	7.4				Y

<< Have minimums been met for this day?

County: Coos Agency: REGION 2

## ENTRY POINT

### EP-A

**PWS ID 4100214**

**GARDEN VALLEY WATER ASSN**

Sample period: Jan 2022  
Month/Year

**Number of excursions during this month: \_\_\_\_\_**

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

RECEIVED

FEB 04 2022

Data Mgmt & Compliance  
Drinking Water Program

**Print Name:** Stephen Pennings

**Signature:** Stephen E Pennings

**Date:** Feb 1st 2022

**Send to DWP within 10 days after end of sampling period**

**No = N = Excursion) Total N's** 0