



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sill	Y/N
1	7.2	40			
2	7.4				
3	7.5				
4	7.3				
5	7.3				
6	7.3				
7	7.2				
8	7.2	60			
9	7.2				
10	7.2				
11	7.3				
12	7.3				
13	7.4				
14	7.4				
15	7.3	60			
16	7.3				
17	7.4				
18	7.3				
19	7.3				
20	7.2				
21	7.2				
22	7.3	60			
23	7.3				
24	7.3				
25	7.3				
26	7.2				
27	7.2				
28	7.3				
29	7.3	60			
30	7.3				
31	7.2				

← Have minimums been met for this day?

County: Clatsop Agency: REGION 2

**ENTRY POINT**

**EP-A**

**PWS ID 4100214**

**GARDEN VALLEY WATER ASSN**

Sample period: Aug 2022  
Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

RECEIVED

SEP 12 2022

**Reference**

Data Mgmt & Compliance  
Drinking Water Program

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.2



Print Name: Ryan A. Sherman

Signature: Ryan A. S.

Date Phone#: 9/5/22 (541) 572-2589

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's