



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.2	40			Y
2	7.2				Y
3					
4					
5					
6	7.3				
7	7.3				
8	7.3	40			
9	7.3				
10	7.3				
11	7.2				
12	7.2				
13	7.2				
14	7.2				
15	7.2	40			
16	7.3				
17	7.3				
18	7.3				
19	7.2				
20	7.2				
21	7.2				
22	7.2	40			
23	7.2				
24	7.2				
25	7.2				
26	7.2				
27	7.2				
28	7.2				
29	7.2				
30	7.2				

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

ENTRY POINT
EP-A

PWS ID 4100214

GARDEN VALLEY WATER ASSN

Sample period: Nov 2022
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Stephen Pennington
 Signature: Stephen Pennington
 Date: Dec 1st 2022

Send to DWP within 10 days after end of sampling period

(= Excursion) Total N's