



# Water Quality Parameter Monitoring Form Certification Lead & Copper Rule Corrosion Control Drinking Water Services

Day	pH	Alk	Phos	Sili	Y/N
1	7.2	40			Y
2	7.2				Y
3	7.2				Y
4	7.2				Y
5	7.3				Y
6	7.2				Y
7	7.2				Y
8	7.2	40			Y
9	7.2				Y
10	7.2				Y
11	7.3				Y
12	7.3				Y
13	7.3				Y
14	7.3				Y
15	7.2	40			Y
16	7.2				Y
17	7.2				Y
18	7.2				Y
19	7.2				Y
20	7.2				Y
21	7.2				Y
22	7.2				Y
23	7.2	40			Y
24	7.2				Y
25	7.2				Y
26	7.2				Y
27	7.2				Y
28	7.2				Y
29	7.2				Y
30	7.2				Y
31	7.2	40			Y

Have minimums been met for this day?

County: Coos Agency: RESOR 2

## ENTRY POINT EP-A

### PWS ID 4100214 GARDEN VALLEY WATER ASSN

Sample period: Dec 2022  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

**Reference**

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Stephen Pennington  
Signature: Stephen Pennington  
Date: 1/10/23

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's 0