



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SM	Y/N
1	7.3	40			Y
2	7.3				Y
3	7.3				
4	7.3				
5	7.2				
6	7.2				
7	7.2				
8	7.2	40			
9	7.2				
10	7.2				
11	7.3				
12	7.2				
13	7.3				
14	7.2				
15	7.2	40			
16	7.2				
17	7.2				
18	7.2				
19	7.2				
20	7.2				
21	7.2				
22	7.2	40			
23	7.2				
24	7.2				
25	7.2				
26	7.2				
27	7.2				
28	7.2				
29	7.2				
30	7.2				
31	7.2				

Have minimums been met for this day?

County: Clatsop Agency: 2000002

ENTRY POINT

EP-A

PWS ID **4100214**

GAISER VALLEY WATER ASSN

Sample period:

Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

Print Name: _____ Ryan Sherman

Signature: _____ Ryan A. R.

Date: _____ 2/1/23 (54)260-2436

Send to DWP within 10 days after end of sampling period

No. of Excursions Total N's