



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sill	Y/N
1	7.2	40			Y
2	7.2				Y
3	7.2				Y
4	7.2				Y
5	7.3				Y
6	7.2				Y
7	7.2	40			Y
8	7.2				Y
9	7.2				Y
10	7.2				Y
11	7.2				Y
12	7.2				Y
13	7.2				Y
14	7.2	40			Y
15	7.3				Y
16	7.2				Y
17	7.2				Y
18	7.2				Y
19	7.2				Y
20	7.2				Y
21	7.2	40			Y
22	7.2				Y
23	7.2				Y
24	7.2				Y
25	7.2				Y
26	7.2				Y
27	7.2				Y
28	7.2	40			Y
29	7.2				Y
30	7.2				Y
31	7.2				Y

Have minimums been met for this day?

County: Clatsop Agency: WEDNET 2

ENTRY POINT
EP-A

PWS ID 4100214

GARDEN VALLEY WATER ASSN

Sample period: March 2023
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Stephen Pennington
 Signature: Stephen Pennington
 Date Printed: April 1st 2023

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's 0