



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.4	40			Y
2	7.4				Y
3	7.4				Y
4	7.4				Y
5	7.4				Y
6	7.4				Y
7	7.4				Y
8	7.4	40			Y
9	7.4				Y
10	7.4				Y
11	7.4				Y
12	7.4				Y
13	7.4				Y
14	7.4				Y
15	7.4	40			Y
16	7.4				Y
17	7.4				Y
18	7.4				Y
19	7.4				Y
20	7.4				Y
21	7.3				Y
22	7.3	40			Y
23	7.3				Y
24	7.3				Y
25	7.3				Y
26	7.3				Y
27	7.3				Y
28	7.3				Y
29	7.3	40			Y
30	7.3				Y
31	7.3				Y

<<Have minimums been met for this day?

County: Coos Agency: REGION 2

ENTRY POINT

EP-A

PWS ID 4100214

GARDEN VALLEY WATER ASSN

Sample period: May 2023
Month/Year

RECEIVED

JUN 08 2023

Data Mgmt & Compliance
Drinking Water Program

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Stephen Pennington

Signature: Stephen Pennington

Date Phone#: May 31 2023 541-805-7230

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's 0