



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.4	40			Y
2	7.4				Y
3	7.4				Y
4	7.4				Y
5	7.4				Y
6	7.4				Y
7	7.4				Y
8	7.4	40			Y
9	7.4				Y
10	7.4				Y
11	7.3				Y
12	7.3				Y
13	7.3				Y
14	7.4				Y
15	7.4				Y
16	7.4	40			Y
17	7.4				Y
18	7.4				Y
19	7.4				Y
20	7.4				Y
21	7.4				Y
22	7.4				Y
23	7.4				Y
24	7.4	40			Y
25	7.4				Y
26	7.4				Y
27	7.4				Y
28	7.4				Y
29	7.4				Y
30	7.4				Y
31					

<<Have minimums been met for this day?

County: Coos    Agency: REGION 2

**ENTRY POINT**

**EP-A**

**PWS ID 4100214**

**GARDEN VALLEY WATER ASSN**

Sample period: June / 23  
Month/Year

RECEIVED

JUL 11 2023

Data Mgmt & Compliance  
Drinking Water Program

**Number of excursions during this month: \_\_\_\_\_**

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

**Print Name:** Stephen Pennington

**Signature:** Stephen Pennington

**Date Phone#:** July 3rd 2023

**Send to DWP within 10 days after end of sampling period**

**No = N = Excursion) Total N's** 0