



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sill	Y/N
1	7.5	40			Y
2	7.3				Y
3	7.3				
4	7.3				
5	7.3				
6	7.5				
7	7.5				
8	7.3	40			
9	7.3				
10	7.4				
11	7.4				
12	7.4				
13	7.4				
14	7.4				
15	7.4	40			
16	7.4				
17	7.4				
18	7.4				
19	7.4				
20	7.3				
21	7.3				
22	7.3	40			
23	7.4				
24	7.4				
25	7.4				
26	7.4				
27	7.3				
28	7.3				
29	7.3				
30	7.3				
31	7.3				

Have minimums been met for this day?

County: Clatsop Agency: PWSID 2

**ENTRY POINT
EP-A**

PWS ID 4100214

GARDEN VALLEY WATER ASSN

Sample period: Aug 2023
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Stephen Pennington RA-2

Signature: Stephen Pennington RA-2

Date Phone#: 09/01/2023 541-866-7230

Send to DWP within 10 days after end of sampling period

Excursion) Total N's 0