



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SiH	Y/N
1	7.5	40			Y
2	7.5				Y
3	7.4				Y
4	7.4				Y
5	7.4				Y
6	7.4				Y
7	7.4				Y
8	7.4	40			Y
9	7.4				Y
10	7.4				Y
11	7.4				Y
12	7.4				Y
13	7.4				Y
14	7.3				Y
15	7.3	40			Y
16	7.3				Y
17	7.3				Y
18	7.3				Y
19	7.3				Y
20	7.3				Y
21	7.3				Y
22	7.3				Y
23	7.3	40			Y
24	7.3				Y
25	7.3				Y
26	7.3				Y
27	7.3				Y
28	7.3				Y
29	7.3				Y
30	7.3	40			Y
31					

Have minimums been met for this day?

County: Clatsop Agency: 000002
ENTRY POINT
EP-A
PWS ID 4100214
GARDEN VALLEY WATER ASSN
 Sample period: Sept 20 23
 Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

RECEIVED

OCT 05 2023

Data Mgmt & Compliance
Drinking Water Program

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Stephen Pennington

Signature: Stephen S Pennington

Date: Oct 1st 2023

Send to DWP within 10 days after end of sampling period

No = N = Excursion Total N's 0