



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SM	YAN
1	7.3	40			Y
2	7.3				Y
3	7.3				Y
4	7.3				Y
5	7.3				Y
6	7.3				Y
7	7.3				Y
8	7.3	40			Y
9	7.3				Y
10	7.2				Y
11	7.2				Y
12	7.2				Y
13	7.2				Y
14	7.2				Y
15	7.2				Y
16	7.2	40			Y
17	7.2				Y
18	7.2				Y
19	7.2				Y
20	7.2				Y
21	7.2				Y
22	7.2				Y
23	7.2	40			Y
24	7.3				Y
25	7.3				Y
26	7.3				Y
27	7.3				Y
28	7.3				Y
29	7.3				Y
30	7.3				Y
31					

<4 have minimums been met for this day?

County: Clatsop Agency: 282022

ENTRY POINT

EP-A

PWS ID 4100214

GARDEN VALLEY WATER ASSN

Sample period: Nov 2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Stephen Pennington
Signature: Stephen Pennington
Date: Dec 1st 2023

Send to DWP within 10 days after end of sampling period

No = N = Excursion Total N's 0