



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Flow	SR	YR
1	7.2	40			18
2	7.2				
3	7.2				
4	7.2				
5	7.2				
6	7.2				
7	7.2				
8	7.2	40			
9	7.2				
10	7.2				
11	7.3				
12	7.3				
13	7.3				
14	7.3				
15	7.3	40			
16	7.3				
17	7.3				
18	7.2				
19	7.2				
20	7.2				
21	7.2				
22	7.2				
23	7.2	40			
24	7.2				
25	7.2				
26	7.2				
27	7.2				
28	7.2				
29	7.2				
30	7.2				
31	7.2				

4-4-100
minimums
been met for
this day?

ENTRY POINT
EP-A

PWS ID 4100214
GARDEN VALLEY WATER ASSN

Sample period: Jan 2024
Month/Year

Number of excursions during this month: _____

(Over 3 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

35?

Print Name: Stephen Pennington RAS

Signature: Stephen Pennington

Date Printed: Feb 1st 2024

Send to DWP within 10 days after end of sampling period

No - N - Excursions Total W's 0