



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Flow	SR	YR
1	7.2	40			
2					
3					
4					
5					
6					
7					
8		40			
9					
10					
11	7.3				
12					
13					
14					
15					
16		40			
17					
18	7.2				
19					
20					
21					
22					
23					
24		40			
25					
26					
27					
28					
29					
30					
31					

Have minimums been met for this day?

County: Clatsop Agency: 000002

**ENTRY POINT  
EP-A**

**PWS ID 4100214**

**GARDEN VALLEY WATER ASSN**

Sample period: Feb, 2024  
Month/Year

Number of excursions during this month: \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

**Reference**

Minimum Water Quality Parameters as set by State:

pH 7.2

Alk 35

Print Name: Stephen Pennington  
Signature: Stephen Pennington  
Date Printed: March 12, 2024

Send to DMP within 10 days after end of sampling period

No. of Excursions Total N's 0