



# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Other	Other	Y/N
1	7.2	40.0	----		Y
2	7.2	----	----		Y
3	7.2	----	----		Y
4	7.2	----	----		Y
5	7.3	----	----		Y
6	7.3	----	----		Y
7	7.2	----	----		Y
8	7.2	40.0	----		Y
9	7.2	----	----		Y
10	7.2	----	----		Y
11	7.3	----	----		Y
12	7.4	----	----		Y
13	7.3	----	----		Y
14	7.2	----	----		Y
15	7.4	40.0	----		Y
16	7.2	----	----		Y
17	7.3	----	----		Y
18	7.2	----	----		Y
19	7.3	----	----		Y
20	7.4	----	----		Y
21	7.5	----	----		Y
22	7.5	40.0	----		Y
23	7.4	----	----		Y
24	7.4	----	----		Y
25	7.5	----	----		Y
26	7.5	----	----		Y
27	7.4	----	----		Y
28	7.4	40.0	----		Y
29	7.2	----	----		Y
30	7.4	----	----		Y
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

## ENTRY POINT

### PWS ID: 41 00214

**System Name:** Garden Valley Water Assn

**Entry Point:** EP-A

**Sample Period:** April 2024  
Month/Year

**Number of excursions during this month :** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameter as set by State:**

pH	<u>7.2</u>	
Alk	<u>35 mg/l</u>	(Alkalinity)
Other	-----	
Other	-----	(_____)

**Print Name:** Ryan A. Sherman

**Signature:**

**Date:** May 2, 2024

Send to Drinking Water Program within 10 days after end of sampling period.  
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350  
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>  
 Page 1 of 2