



# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Other	Other	Y/N
1	7.7	40.0	----		Y
2	7.8	----	----		Y
3	7.7	----	----		Y
4	7.7	----	----		Y
5	7.7	----	----		Y
6	7.6	----	----		Y
7	7.6	----	----		Y
8	7.7	50.0	----		Y
9	7.9	----	----		Y
10	7.8	----	----		Y
11	7.8	----	----		Y
12	7.7	----	----		Y
13	7.6	----	----		Y
14	7.7	----	----		Y
15	7.8	50.0	----		Y
16	7.9	----	----		Y
17	8.0	----	----		Y
18	7.8	----	----		Y
19	8.0	----	----		Y
20	7.9	----	----		Y
21	8.0	50.0	----		Y
22	7.9	----	----		Y
23	7.8	----	----		Y
24	7.8	----	----		Y
25	7.9	----	----		Y
26	7.8	----	----		Y
27	7.6	----	----		Y
28	7.9	70.0	----		Y
29	7.9	----	----		Y
30	7.9	----	----		Y
31	7.7	----	----		Y
(No=N=Excursion) Total N's					<b>0</b>

<<Have minimums been met for this day?

## ENTRY POINT

### PWS ID: 41 00214

**System Name:** Garden Valley Water Assn

**Entry Point:** EP-A

**Sample Period:** 2024  
Month/Year

**Number of excursions during this month :** 0

*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** \_\_\_\_\_


*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameter as set by State:**

pH	7.2	
Alk	35 mg/l	(Alkalinity)
Other	-----	
Other	-----	(_____)

**Print Name:** Ryan A. Sherman

**Signature:** 

**Date:** June 3, 2024