



# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Other	Other	Y/N
1	8.6	----	----		Y
2	8.2	----	----		Y
3	8.5	----	----		Y
4	8.3	----	----		Y
5	8.1	----	----		Y
6	7.5	----	----		Y
7	7.8	----	----		Y
8	8.0	----	----		Y
9	7.8	----	----		Y
10	7.9	----	----		Y
11	8.2	----	----		Y
12	7.6	----	----		Y
13	7.8	----	----		Y
14	7.7	----	----		Y
15	7.8	----	----		Y
16	7.9	----	----		Y
17	7.9	----	----		Y
18	7.8	----	----		Y
19	7.7	----	----		Y
20	7.9	----	----		Y
21	7.7	----	----		Y
22	7.8	----	----		Y
23	7.8	----	----		Y
24	7.2	----	----		N
25	7.7	----	----		Y
26	7.9	----	----		Y
27	7.9	----	----		Y
28	7.6	----	----		Y
29	7.9	----	----		Y
30	7.9	----	----		Y
31	7.7	----	----		Y
(No=N=Excursion) Total N's					<b>1</b>

<<Have minimums been met for this day?

## ENTRY POINT

### PWS ID: 41 00214

**System Name:** Garden Valley Water Assn

**Entry Point:** EP-A

**Sample Period:** 2024  
                     *Month/Year*

**Number of excursions during this month :** 1  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** \_\_\_\_\_  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameter as set by State:**

pH	<b>7.2</b>	
Alk	<b>35 mg/l</b>	<i>(Alkalinity)</i>
Other	-----	
Other	-----	<i>(                    )</i>

**Print Name:** Ryan A. Sherman

**Signature:**

**Date:** August 5, 2024