



Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Other | Other | Y/N |
|----------------------------|-----|------|-------|-------|----------|
| 1 | 7.3 | ---- | ---- | | Y |
| 2 | 7.3 | ---- | ---- | | Y |
| 3 | 7.3 | ---- | ---- | | Y |
| 4 | 7.3 | ---- | ---- | | Y |
| 5 | 7.8 | 80.0 | ---- | | Y |
| 6 | 7.4 | ---- | ---- | | Y |
| 7 | 7.3 | ---- | ---- | | Y |
| 8 | 7.6 | ---- | ---- | | Y |
| 9 | 7.7 | ---- | ---- | | Y |
| 10 | 7.4 | ---- | ---- | | Y |
| 11 | 7.4 | 80.0 | ---- | | Y |
| 12 | 7.7 | ---- | ---- | | Y |
| 13 | 7.7 | ---- | ---- | | Y |
| 14 | 7.6 | ---- | ---- | | Y |
| 15 | 7.6 | ---- | ---- | | Y |
| 16 | 7.6 | ---- | ---- | | Y |
| 17 | 7.4 | ---- | ---- | | Y |
| 18 | 7.6 | ---- | ---- | | Y |
| 19 | 7.6 | 80.0 | ---- | | Y |
| 20 | 7.6 | ---- | ---- | | Y |
| 21 | 7.7 | ---- | ---- | | Y |
| 22 | 7.6 | ---- | ---- | | Y |
| 23 | 7.4 | ---- | ---- | | Y |
| 24 | 7.5 | ---- | ---- | | Y |
| 25 | 7.4 | 80.0 | ---- | | Y |
| 26 | 7.5 | ---- | ---- | | Y |
| 27 | 7.4 | ---- | ---- | | Y |
| 28 | 7.6 | ---- | ---- | | Y |
| 29 | 7.5 | ---- | ---- | | Y |
| 30 | 7.4 | ---- | ---- | | Y |
| 31 | 7.5 | 80.0 | ---- | | Y |
| (No=N=Excursion) Total N's | | | | | 0 |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00214

System Name: Garden Valley Water Assn

Entry Point: EP-A

Sample Period: October 2024
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

| | | |
|-------|----------------|---------------------|
| pH | 7.2 | |
| Alk | 35 mg/l | <i>(Alkalinity)</i> |
| Other | ----- | |
| Other | ----- | <i>()</i> |

Print Name: Ryan A. Sherman

Signature: *Ryan A. Sherman*

Date: November 4, 2024