

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Other	Other	Y/N
1	7.4	----	----		Y
2	7.2	----	----		Y
3	7.3	----	----		Y
4	7.4	----	----		Y
5	7.3	----	----		Y
6	7.3	80.0	----		Y
7	7.3	----	----		Y
8	7.4	----	----		Y
9	7.4	----	----		Y
10	7.5	----	----		Y
11	7.4	----	----		Y
12	7.3	----	----		Y
13	7.3	60.0	----		Y
14	7.5	----	----		Y
15	7.3	----	----		Y
16	7.4	----	----		Y
17	7.3	----	----		Y
18	7.2	----	----		Y
19	7.4	----	----		Y
20	7.4	----	----		Y
21	7.2	60.0	----		Y
22	7.4	----	----		Y
23	7.3	----	----		Y
24	7.4	----	----		Y
25	7.3	----	----		Y
26	7.3	----	----		Y
27	7.3	----	----		Y
28	7.2	----	----		Y
29	7.3	60.0	----		Y
30	7.3	----	----		Y
31	7.4	----	----		Y
(No=N=Excursion) Total N's					0

<<Have
minimums been
met for this day?

ENTRY POINT

PWS ID: 41 00214

System Name:

Garden Valley Water Assn

Entry Point:

EP-A

Sample Period:

January 2025

Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.2	
Alk	35 mg/l	(Alkalinity)
Other	-----	
Other	-----	()

Print Name:

Ryan A. Sherman

Signature:

Ryan A. Sherman

Date:

February 6, 2025

Send to Drinking Water Program within 10 days after end of sampling period.

OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350

Phone: (971) 673-0405

Website: <http://healthoregon.org/dwp/>