

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Other	Other	Y/N
1	7.5	----	----		Y
2	7.7	----	----		Y
3	7.8	----	----		Y
4	7.6	80.0	----		Y
5	8.0	----	----		Y
6	7.7	----	----		Y
7	7.6	----	----		Y
8	8.1	----	----		Y
9	7.7	----	----		Y
10	7.8	----	----		Y
11	7.7	80.0	----		Y
12	8.2	----	----		Y
13	7.9	----	----		Y
14	8.0	----	----		Y
15	8.0	----	----		Y
16	8.1	----	----		Y
17	8.4	----	----		Y
18	8.3	80.0	----		Y
19	7.9	----	----		Y
20	8.2	----	----		Y
21	7.8	----	----		Y
22	7.6	----	----		Y
23	7.5	----	----		Y
24	7.6	----	----		Y
25	7.5	80.0	----		Y
26	7.3	----	----		Y
27	7.5	----	----		Y
28	7.3	----	----		Y
29	----	----	----		----
30	----	----	----		----
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00214

System Name: Garden Valley Water Assn

Entry Point: EP-A

Sample Period: 2025

Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.2	
Alk	35 mg/l	(Alkalinity)
Other	-----	
Other	-----	()

Print Name: RYAN A. SHERMAN

Signature: 

Date: March 10, 2025