

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Other	Other	Y/N
1	7.4	40.0	----		Y
2	7.2	----	----		Y
3	7.4	----	----		Y
4	7.5	----	----		Y
5	7.3	----	----		Y
6	6.8	----	----		N
7	7.4	40.0	----		Y
8	7.4	----	----		Y
9	7.3	----	----		Y
10	7.4	----	----		Y
11	7.4	----	----		Y
12	7.4	----	----		Y
13	7.3	----	----		Y
14	7.3	40.0	----		Y
15	7.3	----	----		Y
16	7.5	----	----		Y
17	7.5	----	----		Y
18	7.5	----	----		Y
19	7.5	----	----		Y
20	7.5	----	----		Y
21	7.5	40.0	----		Y
22	7.5	----	----		Y
23	7.5	----	----		Y
24	7.5	----	----		Y
25	7.4	----	----		Y
26	7.5	----	----		Y
27	7.4	----	----		Y
28	7.5	40.0	----		Y
29	7.4	----	----		Y
30	7.5	----	----		Y
31	----	----	----		----
(No=N=Excursion) Total N's					1

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00214

System Name: Garden Valley Water Assn

Entry Point: EP-A

Sample Period: April 2025

Month/Year

Number of excursions during this month : 1

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	<u>7.2</u>	
Alk	<u>35 mg/l</u>	(Alkalinity)
Other	-----	
Other	-----	()

Print Name:

Signature:

Date:

Ryan A. Sherman
Ryan A. Sherman
May 5, 2025

Send to Drinking Water Program within 10 days after end of sampling period.

OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350

Phone: (971) 673-0405

Website: <http://healthoregon.org/dwp/>